



Royal Pipe Systems™

131 Regalcrest Court
Woodbridge, ON L4L 8P3
Tel: (905) 856-7550
Fax: (905) 856-4367
Toll free: 1-800-263-2353

TECHNICAL SPECIFICATION

PVC Rigid Conduit Fittings Double Gang Boxes-F Series

SCOPE

This specification covers the requirements for Rigid PVC Non-Metallic Double Gang Boxes. These boxes are certified to the Canadian Standards Association (CSA) standard C22.2 Nos. 85 and 18.2 and Underwriters Laboratories (UL) Standard 514C. These boxes also meet all requirements of NEMA OS2-2003. The following are the individual trade names/configurations:

RFS2-10, RFS2-15, RFS2-20, RFSS2-10, RFSS2-15, RFSS2-20

RFSC2-10, RFSC2-15, RFSC2-20, RFSCC2-10, RFSCC2-15, RFSCC2-20, RFD-2

MATERIALS

The PVC material used in the manufacture of these boxes is UV and impact resistant.

MARKING

Double Gang Box markings are as specified in CSA C22.2 Nos. 85 and 18.2 and UL 514C.

BOX CONFIGURATIONS

Double Gang Boxes are available in various configurations, with sockets to accommodate ½" (10), ¾" (15) and 1" (20) PVC rigid conduit. Individual box dimensions are available upon request.

Prepared: August 31, 2006
By: S. Scott
Revised: February 13, 2009